Vanguard Laboratory
2635 Parkmont Lane SW
Olympia, WA 98502
360.967.7010

Report of Laboratory Analysis

Collected by:

Kimera Chems
762-499-2475
Sampling Address:
30 N Gould Street
Sheridan , WY 82801

Matrix Drinking Water
Laboratory ID: V260713-29
Date Sampled: 7/12/26 12:00
Date Received: 7/13/26 16:48
Date Reported: 7/20/2026

Sample ID: **Non-filtered water**

Analysis	Result	SDRL	MCL	Units	DF	Date Analyzed
Nitrate by Hach Method 10206				Batch ID:V260713-29		Analyst: FWH
Nitrate (as N)	ND	0.50	10.00	mg/L	1	7/14/26 17:00
Metals by EPA 200.8				Batch ID: 260713		Analyst: VJ
Lead (Pb)	ND	1.000	15.000	µg/L	1	7/13/2026
Copper (Cu)	ND	20.000	1300.000	µg/L	1	7/13/2026
Conductivity by SM4500-Cl-C				Batch ID:V260713-29		Analyst: FWH
Conductivity	111.300	70.000	700.000	uS/cm	1	7/14/2026
Total Dissolved Solids (TDS) by SM2540C				Batch ID:V260713-29		Analyst: FWH
TDS	81.210	100.000	300.000	ppm	1	7/14/2026
Hardness as CaCO3 by HACH TNT869				Batch ID:V260713-29		Analyst: FWH
Hardness as CaCO3	ND	10.000	-	ppm CaCO3	1	7/14/2026

Notes:
MPN: Most Probable Number
ppm: parts per million
nd: non-detect
n/a: not applicable
SDRL: State Detection Reporting Limit
DF: Dilution Factor
MCL: Maximum Contaminant Level

Reviewed by Dustin Newman, Laboratory Director on 07/20/2026

Approved by Tori Johnson, Operations Manager on 07/20/2026

ISO 17025:2017 ACCREDITED LABORATORY

Samples were received in acceptable condition. The result(s) in this report relate only to the portion of the sample(s) tested. All analyses were performed consistent with the Quality Assurance program of Vanguard Laboratory. Please contact the laboratory if you should have any questions about the results.

Vanguard Laboratory
2635 Parkmont Lane SW
Olympia, WA 98502
360.967.7010

Report of Laboratory Analysis

Collected by:

Kimera Chems
762-499-2475
Sampling Address:
30 N Gould Street
Sheridan , WY 82801

Matrix Drinking Water
Laboratory ID: V260713-29
Date Sampled: 7/12/26 12:00
Date Received: 7/13/26 16:48
Date Reported: 7/20/2026

Sample ID: **Non-filtered water**

Analysis	Result	SDRL	MCL	Units	DF	Date Analyzed
Turbidity by SM2130B				Batch ID: V260622-24		Analyst: FWH
Turbidity	0.7	0.100	-	NTU	1	7/14/2026
Chloride by HACH TNT879				Batch ID: V260622-24		Analyst: FWH
Chloride	ND			mg/L	1	7/14/2026
Fluoride by HACH TNT878				Batch ID: V260622-24		Analyst: FWH
Fluoride as F-	2.350		-	mg/L	1	7/14/2026

Notes:
MPN: Most Probable Number
ppm: parts per million
nd: non-detect
n/a: not applicable
SDRL: State Detection Reporting Limit
DF: Dilution Factor
MCL: Maximum Contaminant Level

Reviewed by Dustin Newman, Laboratory Director on 07/20/2026

Approved by Tori Johnson, Operations Manager on 07/20/2026

ISO 17025:2017 ACCREDITED LABORATORY

Samples were received in acceptable condition. The result(s) in this report relate only to the portion of the sample(s) tested. All analyses were performed consistent with the Quality Assurance program of Vanguard Laboratory. Please contact the laboratory if you should have any questions about the results.

Vanguard Laboratory
2635 Parkmont Lane SW
Olympia, WA 98502
360.967.7010

Report of Laboratory Analysis

Collected by:

Kimera Chems
762-499-2475
Sampling Address:
30 N Gould Street
Sheridan , WY 82801

Matrix Drinking Water
Laboratory ID: V260713-29
Date Sampled: 7/12/26 12:00
Date Received: 7/13/26 16:48
Date Reported: 7/20/2026

Sample ID: **Filtered water**

Analysis	Result	SDRL	MCL	Units	DF	Date Analyzed
Nitrate by Hach Method 10206				Batch ID:V260713-29		Analyst: FWH
Nitrate (as N)	ND	0.50	10.00	mg/L	1	7/14/26 17:00
Metals by EPA 200.8				Batch ID: 260713		Analyst: VJ
Lead (Pb)	ND	1.000	15.000	µg/L	1	7/13/2026
Copper (Cu)	ND	20.000	1300.000	µg/L	1	7/13/2026
Conductivity by SM4500-Cl-C				Batch ID:V260713-29		Analyst: FWH
Conductivity	36.040	70.000	700.000	uS/cm	1	7/14/2026
Total Dissolved Solids (TDS) by SM2540C				Batch ID:V260713-29		Analyst: FWH
TDS	26.360	100.000	300.000	ppm	1	7/14/2026
Hardness as CaCO3 by HACH TNT869				Batch ID:V260713-29		Analyst: FWH
Hardness as CaCO3	ND	10.000	-	ppm CaCO3	1	7/14/2026

Notes:
MPN: Most Probable Number
ppm: parts per million
nd: non-detect
n/a: not applicable
SDRL: State Detection Reporting Limit
DF: Dilution Factor
MCL: Maximum Contaminant Level

Reviewed by Dustin Newman, Laboratory Director on 07/20/2026

Approved by Tori Johnson, Operations Manager on 07/20/2026

ISO 17025:2017 ACCREDITED LABORATORY

Samples were received in acceptable condition. The result(s) in this report relate only to the portion of the sample(s) tested. All analyses were performed consistent with the Quality Assurance program of Vanguard Laboratory. Please contact the laboratory if you should have any questions about the results.

Vanguard Laboratory
2635 Parkmont Lane SW
Olympia, WA 98502
360.967.7010

Report of Laboratory Analysis

Collected by:

Kimera Chems
762-499-2475
Sampling Address:
30 N Gould Street
Sheridan , WY 82801

Matrix Drinking Water
Laboratory ID: V260713-29
Date Sampled: 7/12/26 12:00
Date Received: 7/13/26 16:48
Date Reported: 7/20/2026

Sample ID: **Filtered water**

Analysis	Result	SDRL	MCL	Units	DF	Date Analyzed
Turbidity by SM2130B				Batch ID: V260622-24		Analyst: FWH
Turbidity	0.3	0.100	-	NTU	1	7/14/2026
Chloride by HACH TNT879				Batch ID: V260622-24		Analyst: FWH
Chloride	ND			mg/L	1	7/14/2026
Fluoride by HACH TNT878				Batch ID: V260622-24		Analyst: FWH
Fluoride as F-	ND		-	mg/L	1	7/14/2026

Notes:
MPN: Most Probable Number
ppm: parts per million
nd: non-detect
n/a: not applicable
SDRL: State Detection Reporting Limit
DF: Dilution Factor
MCL: Maximum Contaminant Level

Reviewed by Dustin Newman, Laboratory Director on 07/20/2026

Approved by Tori Johnson, Operations Manager on 07/20/2026

ISO 17025:2017 ACCREDITED LABORATORY

Samples were received in acceptable condition. The result(s) in this report relate only to the portion of the sample(s) tested. All analyses were performed consistent with the Quality Assurance program of Vanguard Laboratory. Please contact the laboratory if you should have any questions about the results.